

## SAFETY DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. PHC/payasampalli/2024/011

Date: 15/04/2024

It is certified that an inspection team headed by DR. K. KALAHASTEESWARA REDDY  
 (Name of officers with designation) from CIVIL ASSISTANT SURGEON.....PHED

inspected DAV BHARATHI VIDYA MANDIR, Nallalingayapalli (Village) Kamalapuram(Mandal), YSR Kadapa(Dist.), Andhra Pradesh. (Name & Address of the school) on 15/04/2024.....

(date of inspection) and on the basis of Water Test Report (Attached) bearing No:

BCCPL/Environment/2024/021 date: 12.04.2024 of BCCPL Environmental Division (PHED Lab)

Certified that the DAV BHARATHI VIDYA MANDIR (Name of school) has safe drinking water facilities for the students and members of staff of the institution / school is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the central /state/U.T. Govt.

This certified is valid till 3 years.....

Signature with seal:

Name:

Designation:

Name &amp; Address of Department/Office:

To

The Principal,

DAV BHARATHI VIDYA MANDIR,

Nallalingayapalli (Village)

Kamalapuram (mandal)

YSR Kadapa (Dist), Andhra Pradesh.

(Name &amp; Address of the Institution)

DR. K. KALAHASTEESWARA REDDY  
 MEDICAL OFFICER  
 PHC-PAYASAMPALLI  
 KAMALAPURAM (M)  
 YSR KADAPA (D)

DR. KALAHASTEESWARA REDDY  
 C.A.S. (MEDICAL OFFICER)

PHC - payasampalli

Kamalapuram (Mandal)  
YSR - Kadapa (AP)

Note: The certificate is to be issued by authorized officer/PHED Lab /local bodies

File No: BCCPL/Environment/2024/021

Date: 12.04.2024

Place: Nallalingayapalli

To  
The Principal,  
DAV Bharathi Vidya Mandir,  
Nallalingayapalli (Village),  
Kamalapuram(Mandal),  
YSR-KADAPA-P-516289.

Sir,

Sub: BCCPL Environment Division -Submission of Drinking Water Sample Test Results-  
Received from DAV BHARATHI VIDYA MANDIR SCHOOL-Req.

It is here with furnishing the Drinking Water sample results which were received from DAV  
Bharathi Vidya Mandir School, Nallalingayapalli (Village), Kamalapuram (Mandal), YSR Kadapa  
on Dt: 12.04.2024

	Parameters	PH	A	P-alk	M-alk	TH	CaH	MgH	Cl	Silica	Turbidity	Res. Cl2
At DAV Bharathi Vidya Mandir, Nallalingayapalli, Kamalapuram, YSR Kadapa.												
	units		us/cm	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	NTU	mg/L
	Results	7.08	93.6	<0.1	43.9	45.6	44.1	1.5	27.2	0.03	<1.0	0.4

Note: The drinking water is safe for drinking purpose.

*Ready*  
*Chetty*  
Chief Chemist(I/C)

Chief Chemist  
Bharathi Cement Corporation Private Limited,  
Nallalingayapalli-516289,  
Kamalapuram (Mandal)  
Dt: YSR Kadapa,



Vicat, France

Corporate Office: 8-2-626, Reliance Majestic, Road No.10, Banjara Hills, Hyderabad - 500 034. Ph: +91 40 3000 6999, Fax: +91 40 3000 6977



/BharathiCements



/BharathiCements



Scanned with OKEN Scanner



Right Choice

# UNIVERSAL ENVIRO ASSOCIATES

SINCE 1994

Recognised by NABL and  
MoEF & CC, GOI, New Delhi.

Certified by ISO 9001 : 2015 and  
ISO 45001 : 2018

## TEST REPORT

REGD NO: UEA/BCCPL/R1-1/0324


Date: 11-03-2024

### DRINKING WATER ANALYSIS

Name of the Industry & Address : **M/s. Bharathi Cement Corporation Pvt. Ltd.,**  
Nallalingayapalli (V), Kamalapuram (M),  
Y.S.R.Kadapa(Dist.)

Sample Particulars : Drinking water – DAV BHARATHI VIDYA MANDIR  
Date of collection : 04-03-2024  
Date of Analysis : 05-03-2024

S No	Parameters	Test Result	Specification as per IS:10500:2012		Test Method
			Desirable	Permissible	
1	Colour, Hazen Units	<1.0	Max 5	Max 15	IS:3025(P-4)2012
2	Odour	Agreeable	Agreeable	Agreeable	IS:3025(P-5)2012
3	pH @ 25 Deg C	7.08	6.5-8.5	No Relax <sup>n</sup>	IS:3025(P-11)2012
4	Electrical Conductivity, $\mu\text{s}/\text{cm}$	93.6	--	--	APHA 23 <sup>rd</sup> Edition: 2017, 2510 B
5	Turbidity, NTU	<1.0	Max 1	Max 5	IS:3025(P-10)2012
6	P-Alkalinity as $\text{CaCO}_3$ , mg/L	<0.1	--	--	IS:3025(P-23)2012
7	M-Alkalinity as $\text{CaCO}_3$ , mg/L	43.9	Max 200	Max 600	IS:3025(P-23)2012
8	Total Hardness as $\text{CaCO}_3$ , mg/L	45.6	Max 200	Max 600	IS:3025(P-21)2012
9	Silica as $\text{SiO}_2$ , mg/L	0.03	0.05	No Relaxation	APHA 23 <sup>rd</sup> Edition: 2017, 4500 $\text{SiO}_2$ C
10	Calcium as $\text{CaCO}_3$ , mg/L	44.1	Max 75	Max 200	IS:3025(P-40)2012
11	Magnesium as $\text{CaCO}_3$ , mg/L	1.5	Max 30	Max 100	IS:3025(P-46)2012
12	Residual Chlorine as $\text{R.Cl}_2$ , mg/L	0.4	Max 250	Max 1000	IS:3025(P-32)2012
13	Chlorides as Cl, mg/L	27.2	Max 250	Max 1000	IS:3025(P-32)2012

  
Analyst

  
Authorized Signatory

# 178, Ramakrishna Nagar, Opp. IOCL, Chengicherla, Hyderabad - 500 039.

Ph: 040 - 4890 8772, e-mail: uea123@gmail.com, www.universalenviro.in

WTP, STP, ETP & ZLD (Supply, O&M) | POLLUTION TESTING & ANALYSIS | ENV. AUDIT | OTHER ENV. SERVICES

Note: This report is subject to the terms and conditions mentioned overleaf



Scanned with OKEN Scanner